



t1.800.444.4554 Opt.2 f1.800.777.3929

August 27, 2018

Mr. Bob Anderson, Chief TRI DISTRICT FPSA PO BOX 734 Claremore, Oklahoma, 74018

RE: Tri District Fpsa, Rogers County, Oklahoma Public Protection Classification: 03/10 Effective Date: December 01, 2018

Dear Mr. Bob Anderson,

We wish to thank you and Chief Bob Anderson for your cooperation during our recent Public Protection Classification (PPC) survey. ISO has completed its analysis of the structural fire suppression delivery system provided in your community. The resulting classification is indicated above.

If you would like to know more about your community's PPC classification, or if you would like to learn about the potential effect of proposed changes to your fire suppression delivery system, please call us at the phone number listed below.

ISO's Public Protection Classification Program (PPC) plays an important role in the underwriting process at insurance companies. In fact, most U.S. insurers – including the largest ones – use PPC information as part of their decision- making when deciding what business to write, coverage's to offer or prices to charge for personal or commercial property insurance.

Each insurance company independently determines the premiums it charges its policyholders. The way an insurer uses ISO's information on public fire protection may depend on several things – the company's fire-loss experience, ratemaking methodology, underwriting guidelines, and its marketing strategy.

Through ongoing research and loss experience analysis, we identified additional differentiation in fire loss experience within our PPC program, which resulted in the revised classifications. We based the differing fire loss experience on the fire suppression capabilities of each community. The new classifications will improve the predictive value for insurers while benefiting both commercial and residential property owners. We've published the new classifications as "X" and "Y" — formerly the "9" and "8B" portion of the split classification, respectively. For example:

- A community currently graded as a split 6/9 classification will now be a split 6/6X classification; with the "6X" denoting what was formerly classified as "9."
- Similarly, a community currently graded as a split 6/8B classification will now be a split 6/6Y classification, the "6Y" denoting what was formerly classified as "8B."

- Communities graded with single "9" or "8B" classifications will remain intact.
- Properties over 5 road miles from a recognized fire station would receive a class 10.

PPC is important to communities and fire departments as well. Communities whose PPC improves may get lower insurance prices. PPC also provides fire departments with a valuable benchmark, and is used by many departments as a valuable tool when planning, budgeting and justifying fire protection improvements.

ISO appreciates the high level of cooperation extended by local officials during the entire PPC survey process. The community protection baseline information gathered by ISO is an essential foundation upon which determination of the relative level of fire protection is made using the Fire Suppression Rating Schedule.

The classification is a direct result of the information gathered, and is dependent on the resource levels devoted to fire protection in existence at the time of survey. Material changes in those resources that occur after the survey is completed may affect the classification. Although ISO maintains a pro-active process to keep baseline information as current as possible, in the event of changes please call us at 1-800-444-4554, option 2 to expedite the update activity.

ISO is the leading supplier of data and analytics for the property/casualty insurance industry. Most insurers use PPC classifications for underwriting and calculating premiums for residential, commercial and industrial properties. The PPC program is not intended to analyze all aspects of a comprehensive structural fire suppression delivery system program. It is not for purposes of determining compliance with any state or local law, nor is it for making loss prevention or life safety recommendations.

If you have any questions about your classification, please let us know.

Sincerely,

Alex Shubert

Alex Shubert

Manager - National Processing Center

cc:

Charles Tipton, Water Superintendent, ROGERS COUNTY RWD #7 Chief Bob Anderson, Fire Chief, Tri District Fire Department Ms. Vicki Atchley, 911 Director, Rogers County 911

## HYDRANT FLOW DATA SUMMARY INSURANCE SERVICES OFFICE, INC.

City	Tri District Fpsa	Fpsa	State	OKLAHOMA (35)	Wit	nessed by:	Witnessed by: Insurance Services Office	vices Office			Date:	Date: Oct 12, 2017	
County	County Oklanoma(Rogers),	Kogers),											
					FLOW-GPM	GPM		PRESSURE	SURE	FLOW -AT 20 PSI	T 20 PSI		
					$Q=(29.83(C(d^2)p^{0.5}))$	$C(\mathbf{d}^2)\mathbf{p}^{0.5}))$		PSI	51				
TEST	TVPE	TEST LOCATION	SERVICE	IND	INDIVIDUAL		TOTAL	STATIC	RESID.	NEEDED AVAIL.	AVAIL.	REMARKS***	MODEL TYPE
100	DICT *			ΥН	HYDRANTS					*			
TIM!	DAO A.	8 UVH	Fire Department Supply	0	0	0	1150	0	0	3500	1150		CIK
IWI		HVD 76	Fire Department Supply	0	0	0	650	0	0	1250	650		CTR
7MH		HID /0	Fin Donostmont Supply	O G	0	0	1350	0	0	750	1350		CTR
HW3		HYDIO	File Department Supply			0	1150	0	0	750	1150		CTR
HW4		НУДУ	r lle Department Suppry			٥	1150	0	0	500	1150		CTR
HW5		HYD 37	Fire Department Supply	C	C	c	1100	•			1		
		9											

THE ABOVE LISTED NEEDED FIRE FLOWS ARE FOR PROPERTY INSURANCE PREMIUM CALCULATIONS ONLY AND ARE NOT INTENDED TO PREDICT THE MAXIMUM AMOUNT OF WATER REQUIRED FOR A LARGE SCALE FIRE CONDITION.

THE AVAILABLE FLOWS ONLY INDICATE THE CONDITIONS THAT EXISTED AT THE TIME AND AT THE LOCATION WHERE TESTS WERE WITNESSED.

<sup>\*</sup>Comm = Commercial; Res = Residential.

<sup>\*\*</sup>Needed is the rate of flow for a specific duration for a full credit condition. Needed Fire Flows greater than 3,500 gpm are not considered in determining the classification of the city when using the Fire Suppression Rating Schedule.

\*\*\*\* (A)-Limited by available hydrants to gpm shown. Available facilities limit flow to gpm shown plus consumption for the needed duration of (B)-2 hours, (C)-3 hours or (D)-4 hours.